


IDENTIFYING TIE MARKER

NOTES:

1. DEPTH: MINIMUM 36" - MAXIMUM 48" COMPACTED TO 95%
2. SCHEDULE 40 PVC GLUED AND AIRTIGHT
3. TYPICAL ELECTRIC TRENCH LINE 18" BEHIND THE WALK
4. ALL LPC CROSSINGS SHALL BEGIN AND END IN THE ELECTRIC EASEMENT OR OUTLOT.
5. EXTEND LPC CROSSINGS 3' BEYOND THE CURB OR SIDEWALK.
6. OTHER UTILITY CROSSINGS SHALL BE LOCATED AND MARKED WITH A STAKE. THE STAKE SHALL IDENTIFY THE SIZE AND DEPTH OF THE CROSSING.
7. EXTEND OTHER UTILITY CROSSINGS BEYOND THE ELECTRIC EASEMENT.
8. GAS CROSSINGS SHALL MAINTAIN 5' CLEARANCE FROM ELECTRIC
9. COMMUNICATIONS CROSSINGS MAY SHARE A TRENCH WITH LPC AND MUST BE AT A MINIMUM DEPTH OF 36" IN THE LPC EASEMENT.

	SLEEVE INSTALLATION		
	REV.	700-03	SCALE: NA
POWER & COMMUNICATIONS	DATE: DECEMBER 2003	DRAWN BY: RAWTMF	APPROVAL: